

TOWN OF NEW MARKET – SHADY LANE STREET IMPROVEMENT PROJECT

ADDENDUM # 2

- 1. THERE IS NO MINIMUM LEVEL OF PARTICIPATION FOR DBE/MBE/WBE AS THERE IS NO FEDERAL FUNDS ON THIS PROJECT. VDOT ENCOURAGES BIDDERS TO MAKE AN ATTEMPT TO ACHIEVE A 10% PARTICIPATION LEVEL FROM DBE/MBE/WBE HOWEVER THIS LEVEL IS NOT MANDATORY. IF THE CONTRACTOR HAS A DBE PARTICIPATING THEY WILL BE REQUIRED TO SUBMIT FORM C 63 PRIOR TO FINAL AWARD OF THE CONTRACT.**
- 2. ITEM 8 IN ADDENDUM NO. 1 IS RECINDED. NON-POLISHING AGREGATE WILL BE REQUIRED IN ALL SURFACE ASPHALT PAVEMENTS.**
- 3. THE 48 HOUR INSPECTION NOTIFICATION IS NOT MANDATORY. VDOT REQUEST THAT THE CONTRACTOR GIVE THEM AS MUCH LEAD NOTIFICATION AS POSSIBLE PRIOR TO THE NEEDED INSPECTION.**
- 4. ONE CONCRETE CYLINDER TEST WILL BE REQUIRED PER 1000 LINEAL FEET OF CURB AND GUTTER.**
- 5. IN ADDITION TO A MARKED UP SET OF AS-BUILT PLANS THE CONTRACTOR SHALL PROVIDE A SURVEY CERTIFICATION THAT ALL FACILITIES HAVE BEEN INSTALLED WITHIN THE VDOT RIGHT OF WAY.**
- 6. THE CONTRACTOR AWARDED THE CONTRACT SHALL BE REQUIRED TO HAVE AN EMPLOYEE WITH VDOT EROSION AND SEDIMENT CONTROL CONTRACTOR CERTIFICATION.**
- 7. THE ORIGINAL SIGN IN SHEET OF THE ATTENDEES AT THE PRE-BID CONFERENCE IS ATTACHED ALONG WITH A TYPED SUMMARY.**